



**State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES**

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095

(603) 271-2457 FAX (603) 271-7894



Emily St. John
Wildwood Campground
540 Old Coach Rd
New Boston, New Hampshire 03070

LETTER OF DEFICIENCY
WMB PBF 02-55
August 29, 2002

Dear Ms. St. John:

The Department of Environmental Services, Water Division ("DES") is required by RSA 485-A:26 to operate a program to ensure the health and safety of the public when using public bathing facilities such as pools and spas. To implement this program, DES has adopted administrative rules Env-Ws 1101-1105 to specify the design, operation, and maintenance requirements for public bathing facilities. DES reviews applications for new public bathing facilities and also inspects and tests the water in existing public bathing facilities to ensure that applicable requirements are being met.

On August 14, 2002, DES inspected the pool at the Wildwood Campground in New Boston, NH ("the Pool"). During this inspection the following deficiencies were noted:

- 1 A recommendation to super chlorinate the Pool was issued on August 16, 2002. The inspection on August 14, 2002 revealed that the Pool was in violation of Env-Ws 1103.14 and unsafe for public use. The following bacterial violation was observed in the Pool water:
 - (a) The maximum allowable concentration of non-coliform bacteria in public bathing facility water is two hundred counts per one hundred milliliters (200 CTS/100mL). The Pool water contained greater than 200 CTS/100mL.
2. Pursuant to Env-Ws 1104.03(b), the operator shall be responsible for posting conspicuously displayed signs informing patrons of the DES rules relative to patron responsibilities (enclosed copy) and any other safety rules developed by the bathing facility management. Patron rules were not posted at the Pool at the time of the inspection.
- 3 Pursuant to Env-Ws 1104.03(c), signs shall provide the location of the nearest telephone. The location of the nearest telephone was not posted at the Pool at the time of the inspection.
4. Env-Ws 1104.03(e)(1) states that the depth of water in feet shall be plainly and conspicuously marked at or above the water line on the vertical pool wall and on the top of the coping or edge of the deck or walk next to the pool. The depth of the Pool was not marked on the vertical pool wall of the Pool.
5. Env-Ws 1105.01(k)(19) requires pool filtration systems to include a flow meter. The filtration system for the Pool did not include a flow meter.
6. Pursuant to Env-Ws 1105.01(k)(8), suction outlets shall be provided with a cover that has been tested and approved by a nationally recognized testing laboratory. Flat grates under 10" diameter do not meet the requirements of ANSI/NSF Standard 50 or ASME/ANSI A112.19.8M ("Suction Fittings for use in Swimming Pools, Wading Pool, Spas, Hot Tubs, and Whirlpool Bath Applications"). The Pool has a flat grate under 10" diameter.

A report outlining how compliance will be achieved with the cited deficiencies should be submitted to DES within 30 calendar days from receipt of this letter. The report should include the following:

1. A copy of two weeks of water quality test results for all facilities (please do not send originals).
2. The type, manufacture, and model of the flow meter to be installed.
3. The type, manufacture, and model of the main drain cover to be installed.
4. A timetable of when:
 - a. the safety items will be in place,
 - b. the depth will be marked,
 - c. patron rules will be posted, , and
 - d. the installation of the flow meter will be completed.

DES personnel will conduct another inspection at a later date to determine whether you have come into, and are maintaining, full compliance with RSA 485-A:26 and Env-Ws 1101-1105. After a violation of Env-Ws 1103.14, the facility will be required to pass two inspections in the following months. In the event that compliance is not achieved, DES may take further action, including seeking an administrative fine up to \$2,000 for each offense or referring the case to the NH Attorney General's Office for judicial action.

We appreciate your cooperation in this matter. Please contact Amy Wilson at (603) 271-7108 if you have any questions regarding this letter. Copies of Env-Ws 1101-1105 are available through the DES Public Information Center at (603) 271-2975 or via the Internet at <http://www.des.state.nh.us/pools/env1100.pdf>.

Sincerely,


Jody Connor
Limnology Center Director

enclosures

cc Mark Harbaugh, Enforcement Attorney, DES ✓
Amy Wilson, Public Bathing Facility Coordinator, DES
Dennis Sarette, Health Officer, Town of New Boston

H:\BIOLOGYPOOLS\Letters-LOD\LOD.02.55.doc